

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-1076:132 Page 1 of 1

**CATEGORY:** Control Unit (Non High Rise)

**LISTEE:** Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721  
Contact: Terrill Garland (508) 881-2000

**DESIGN:** Models ANALASER TFP High-Sensitive Smoke Detector\* (HSSD) fire alarm control unit. Local type, automatic, manual, waterflow and sprinkler supervisory service. Units are integral systems consisting of a control unit and separately listed air sampling smoke detection systems (Refer to detector's listing for more details). Refer to listee's data sheet for additional detailed description and operational considerations.

**RATING:** 120 or 240 VAC primary, 24 VDC secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authorities having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with listee's separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 07-16-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager